



Humboldt Bay Municipal Water District Korblex Reservoirs Seismic Retrofit Bid Addendum #3

The purpose of this Addendum is to modify the Contract Documents for the subject project. This Addendum shall become part of said Contract Documents.

Bidders shall acknowledge receipt of this Addendum in their bid proposal.

This Addendum addresses the following items and questions:

1. Are there Buy America or American Iron and Steel requirements for this project?
 - a. No.
2. Specification 33 16 13 Paragraph B.3 requires a 3-foot radius knuckle between the roof and shell. Detail 3/S-103 (Roof to Wall Connection) does not show the knuckle transition from roof to wall. These two sections of the contract documents conflict with each other, please clarify.
 - a. Specification 33 16 13 Paragraph B.3 shall be stricken in its entirety and revised to state the following:
"The roof shall be cone type. A knuckle between the roof and the shell may be provided at the Contractor's discretion provided that the capacity, wind performance, and seismic performance of the tank is not degraded."
3. Will the Notice to Proceed (NTP) be issued at the same time for the HBMWD Korblex Reservoirs Seismic Retrofit Project and the HBMWD Samoa Reservoir Seismic Retrofit Project?
 - a. It is anticipated that the NTP for each of these projects will be issued at approximately the same time. However, the District reserves the right to issue the NTP for each respective project at different times due to potential unforeseen circumstances.
4. Section C/S-201 does not show a fillet weld at the bottom of the new reinforcing plate to the floor. Is a bottom fillet weld desired to prevent moisture from getting between the existing shell plate and new reinforcing plate?
 - a. A fillet weld at the bottom of the new reinforcing plate to the floor is shown on Detail 1/S-201.

END OF ADDENDUM

5/28/2024

Date

A handwritten signature in black ink, appearing to read "North Star".

Signature