EST. 1956

HUMBOLDT BAY MUNICIPAL WATER DISTRICT

828 Seventh Street • Eureka, California 95501-1114 PO Box 95 • Eureka, California 95502-0095 Office 707-443-5018 Essex 707-822-2918 Fax 707-443-5731 707-822-8245

EMAIL OFFICE@HBMWD.COM Website: www.hbmwd.com

BOARD OF DIRECTORS

MICHELLE FULLER, PRESIDENT DAVID LINDBERG, VICE PRESIDENT J. BRUCE RUPP, SECRETARY-TREASURER SHERI WOO, DIRECTOR TOM WHEELER, DIRECTOR

GENERAL MANAGER JOHN FRIEDENBACH

Humboldt Bay Municipal Water District On-Site Hypochlorite Generation Project Bid Addenda #1

Bidders shall acknowledge receipt of this Addendum in their bid proposal.

This Addendum addresses the following item:

1. Water Supply line to process. Sheet C-101, Keynote 8

The Bid Drawings show the water supply line under the wash rack concrete slab. This should be moved to either between the concrete slab and the existing chlorine injection line OR between the chlorine injection line and the existing under ground conduit. Where ever there is the most room.

END OF ADDENDUM

10/15/24

Date

Signature